



Smart Grid Standards Information

Version 1.7

Friday, May 14, 2010

Section I: Use and Application of the Standard

A. Identification and Affiliation

1.	Number of the standard	IEC 60870-6-503, IEC 60870-6-703, IEC 60870-6-802
2.	Title of the standard	Telecontrol Application Service Element 2
3.	Name of owner organization	International Electrotechnical Commission
4.	Latest versions, stages, dates	TASE 2 (2005)
5.	URL(s) for the standard	http://www.iec.ch , http://webstore.iec.ch/webstore/webstore.nsf/artnum/034806 http://webstore.iec.ch/webstore/webstore.nsf/artnum/037328 http://webstore.iec.ch/webstore/webstore.nsf/artnum/023285 http://www.iec.ch/cgi-bin/procgi.pl/www/iecwww.p?wwwlang=E&wwwprog=sea22.p&search=ext&searchfor=TASE.2&Submit=OK
6.	Working group / committee	IEC TC57 Working Group 07
7.	Original source of the content (if applicable)	Under Electric Power Research Institute (EPRI) sponsorship, a committee comprised of members from WSCC, IDEC, and ERCOT.
8.	Brief description of scope	Standard for Communications between electric power control centers. Formerly known as Inter Control Center Protocol (ICCP), the standard is used for communication of electric power system status and control messages between power control centers.

B. Level of Standardization

1.	Names of standards development organizations that recognize this standard and/or accredit the owner organization	International Electrotechnical Commission
2.	Has this standard been adopted in regulation or legislation, or is it under consideration for adoption?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
3.	Has it been endorsed or recommended by any level of government? If "Yes", please describe	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Developed in response to European Common Market requirements in 1992.
4.	Level of Standard (check all that apply)	<input checked="" type="checkbox"/> International <input type="checkbox"/> National <input type="checkbox"/> Industry <input type="checkbox"/> de Facto <input type="checkbox"/> Single Company
5.	Type of document	<input checked="" type="checkbox"/> Standard <input type="checkbox"/> Report <input type="checkbox"/> Guide <input type="checkbox"/> Technical Specification

Section I: Use and Application of the Standard

6.	Level of Release	<input checked="" type="checkbox"/> Released <input type="checkbox"/> In Development <input type="checkbox"/> Proposed
----	------------------	--

C. Areas of Use

1.	Currently used in which domains? (check all that apply)	<input type="checkbox"/> Markets <input checked="" type="checkbox"/> Operations <input type="checkbox"/> Service Providers <input checked="" type="checkbox"/> Generation <input checked="" type="checkbox"/> Transmission <input type="checkbox"/> Distribution <input type="checkbox"/> Customer
2.	Planned for use in which domains? (check all that apply)	<input type="checkbox"/> Markets <input checked="" type="checkbox"/> Operations <input type="checkbox"/> Service Providers <input checked="" type="checkbox"/> Generation <input checked="" type="checkbox"/> Transmission <input checked="" type="checkbox"/> Distribution <input type="checkbox"/> Customer
3.	Please describe the Smart Grid systems and equipment to which this standard is applied	This standard is applied for communications between major control centers of the power system including power pool operators. The communications is across secure links between control center computer and information technology systems.

D. Relationship to Other Standards or Specifications

1.	Which standards or specifications are referenced by this standard?	ISO 9506-1, ISO 9506-2 Manufacturing Message Specification (MMS)
2.	Which standards or specifications are related to this standard?	IEC 61970, IEC 61850
3.	Which standards or specifications cover similar areas (may overlap)?	IEC 61970
4.	What activities are building on this work?	Further Development of IEC 61970

E. Dept of Energy Smart Grid Characteristics

Please describe how this standard may encourage each of the following:

1.	Enables informed participation by customers	<input type="checkbox"/> Yes <input type="checkbox"/> No
2.	Accommodates all generation and storage options	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3.	Enables new products, services and markets	<input type="checkbox"/> Yes <input type="checkbox"/> No
4.	Provides the power quality for a range of needs	<input type="checkbox"/> Yes <input type="checkbox"/> No
5.	Optimizes asset utilization and operating efficiency	<input type="checkbox"/> Yes <input type="checkbox"/> No
6.	Operates resiliently to disturbances, attacks, and natural disasters	<input type="checkbox"/> Yes <input type="checkbox"/> No

F. Priority Areas Previously Mentioned by FERC and NIST

Please describe if and how this standard may be applied in each of the following areas. Note that there is space in section **Error! Reference source not found.** to discuss any other significant areas where the standard may be applied.

1.	Cybersecurity and physical security	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
2.	Communicating and coordinating across inter-system interfaces	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3.	Wide area situational awareness	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
4.	Smart grid-enabled response for energy demand	<input type="checkbox"/> Yes <input type="checkbox"/> No
5.	Electric storage	<input type="checkbox"/> Yes <input type="checkbox"/> No
6.	Electric vehicle transportation	<input type="checkbox"/> Yes <input type="checkbox"/> No
7.	Advanced metering infrastructure	<input type="checkbox"/> Yes <input type="checkbox"/> No
8.	Distribution grid management	<input type="checkbox"/> Yes <input type="checkbox"/> No

G. Openness		
1.	Amount of fee (if any) for the documentation	Approx 700 Swiss Franc
2.	Amount of fee (if any) for implementing the standard	None
3.	Amount of fee (if any) to participate in updating the standard	Annual National Committee Dues for Participation on TC 57 (\$300 US\$)
4.	Is the standard documentation available online?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No URL: http://webstore.iec.ch/webstore/webstore.nsf/artnum/023285
5.	Are there open-source or reference implementations?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
6.	Are there open-source test tools?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
7.	Would open-source implementations be permitted?	<input type="checkbox"/> Yes <input type="checkbox"/> No
8.	Approximately how many implementers are there?	Dozens Estimated
9.	Approximately how many users are there?	Hundreds Estimated
10.	Where is the standard used outside of the USA?	Worldwide
11.	Is the standard free of references to patented technology?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
12.	If patented technology is used, does the holder provide a royalty-free license to users of the standard?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Not Patented
13.	Can an implementer use the standard without signing a license agreement?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
14.	Are draft documents available to the public at no cost?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
15.	How does one join the working group or committee that controls the standard?	Become a member of IEC TC 57
16.	Is voting used to decide whether to modify the standard? If Yes, explain who is permitted to vote.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No IEC Governance Rules Apply. One vote per country
17.	Is an ANSI-accredited process used to develop the standard?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
18.	What countries are represented in the working group or committee that controls the standard?	
H. Support, Conformance, Certification and Testing		
1.	Is there a users group or manufacturers group to support this standard?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
2.	What is the name of the users group or manufacturers group (if any)?	UCA International Users Group
3.	What type of test procedures are used to test this standard? (please check all that apply)	<input type="checkbox"/> Internal to the lab <input type="checkbox"/> Published by standards organization <input type="checkbox"/> Published by users group <input checked="" type="checkbox"/> No procedures, informal testing
4.	Are there test vectors (pre-prepared data) used in testing? (please check all that apply)	<input type="checkbox"/> Internal to the lab <input type="checkbox"/> Published by standards organization <input type="checkbox"/> Published by users group <input checked="" type="checkbox"/> No procedures, informal testing

5.	What types of testing programs exist? (check all that apply)	<input type="checkbox"/> Interoperability Testing <input checked="" type="checkbox"/> Conformance Testing <input type="checkbox"/> Security Testing <input type="checkbox"/> No Testing
6.	What types of certificates are issued? (check all that apply)	<input type="checkbox"/> Interoperability Certificate <input type="checkbox"/> Conformance Certificate <input type="checkbox"/> Security Certificate (text document) <input checked="" type="checkbox"/> No Certificates
7.	Are there rules controlling how and when to use the logo?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Standard has no logo
8.	Is there a program to approve test labs?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
9.	Approximately how many test labs are approved (if any)?	
10.	Is there a defined process for users to make technical comments on the standard or propose changes to the standard and have these issues resolved?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
11.	Is there a published conformance checklist or table?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
12.	Are there defined conformance blocks or subsets?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
13.	Approximately how many vendors provide test tools?	3
14.	Are there tools for pre-certification prior to testing?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
15.	Can vendors self-certify their implementations?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
16.	Is there application testing for specific uses?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
17.	Is there a "golden" or "reference" implementation to test against?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
18.	Who typically funds the testing? (check all that apply)	<input checked="" type="checkbox"/> User <input type="checkbox"/> Users Group <input checked="" type="checkbox"/> Vendor <input type="checkbox"/> Confidential
19.	Is there a method for users and implementers to ask questions about the standard and have them answered? (check all that apply)	<input type="checkbox"/> Yes, official interpretations <input checked="" type="checkbox"/> Yes, informal opinions <input type="checkbox"/> No
20.	Does the users' group (or some other group) fund specific tasks in the evolution of the standard?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
21.	Is the users' group working on integration, harmonization or unification with other similar standards?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
22.	What other standards is this standard being integrated, harmonized, or unified with (if any)?	It might be considered to integrate with IEC 61970 but this has not begun
23.	Are there application notes, implementation agreements, or guidelines available describing specific uses of the standard?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable

J. Notes

Please present here any additional information about the standard that might be useful:

1. This is one of the most widely used standards in the world of this type.

Section II: Functional Description of the Standard

K. GridWise Architecture: Layers

Please identify which layers this standard specifies, as described in

http://www.gridwiseac.org/pdfs/interopframework_v1_1.pdf, and the applicable section of the standard. Note the mapping to the Open Systems Interconnect (OSI) model is approximate.

1.	Layer 8: Policy	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
2.	Layer 7: Business Objectives	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
3.	Layer 6: Business Procedures	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
4.	Layer 5: Business Context	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
5.	Layer 4: Semantic Understanding (object model)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
6.	Layer 3: Syntactic Interoperability (OSI layers 5-7)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
7.	Layer 2: Network Interoperability (OSI layers 3-4)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
8.	Layer 1: Basic Connectivity (OSI layers 1-2)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

L. GridWise Architecture: Cross-Cutting Issues

Please provide an explanation in the box beside the heading for any questions answered "Not applicable". If the question is not applicable because the function is provided in another layer or standard, please suggest any likely candidates. Note that "the standard" refers to the technology specified by the standard, not the documents themselves.

	Shared Meaning of Content	
1.	Do all implementations share a common information model?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
2.	Can data be arranged and accessed in groups or structures?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not applicable
3.	Can implementers extend the information model?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
4.	Can implementers use a subset of the information model?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
	Resource Identification	
5.	Can data be located using human-readable names?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
6.	Can names and addresses be centrally managed without human intervention?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
	Time Synchronization and Sequencing	
7.	Can the standard remotely synchronize time?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Provided in another layer
8.	Can the standard indicate the quality of timestamps?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Provided in another layer
	Security and Privacy	
9.	Where is security provided for this standard?	<input type="checkbox"/> Within this standard <input checked="" type="checkbox"/> By other standards
10.	Does the standard provide authentication?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
11.	Does the standard permit role-based access control?	<input type="checkbox"/> Yes <input type="checkbox"/> No

Section II: Functional Description of the Standard

12.	Does the standard provide encryption?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
13.	Does the standard detect intrusions or attacks?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
14.	Does the standard facilitate logging and auditing of security events?	<input type="checkbox"/> Yes <input type="checkbox"/> No
15.	Can the security credentials be upgraded remotely?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> No Credentials
16.	Can the security credentials be managed centrally?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> No Credentials
17.	Please list any security algorithms and standards used	
18.	Please provide additional information on how the standard addresses any "Yes" answers above	
19.	Please provide additional information about why any of the questions listed above do not apply to this standard	
Logging and Auditing		
20.	Does the standard facilitate logging and auditing of critical operations and events?	<input type="checkbox"/> Yes <input type="checkbox"/> No
21.	Can the standard gather statistics on its operation?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
22.	Can the standard report alerts and warnings?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
Transaction State Management		
23.	Can the standard remotely enable or disable devices or functions?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
System Preservation		
24.	Can the standard automatically recover from failed devices or links?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable <input type="checkbox"/> Provided in another layer
25.	Can the standard automatically re-route messages?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable <input type="checkbox"/> Provided in another layer
26.	Can the standard remotely determine the health (as opposed to just connectivity) of devices or software?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
Other Management Capabilities		
27.	Please describe any other system or network management capabilities the standard provides.	
Quality of Service		
28.	Is data transfer bi-directional?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
29.	Can data be prioritized?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
30.	What types of reliability are provided?	<input type="checkbox"/> Reliable <input type="checkbox"/> Non-guaranteed <input type="checkbox"/> Both <input type="checkbox"/> Either <input checked="" type="checkbox"/> Provided in another layer
31.	Can information be broadcast to many locations with a single transmission?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
32.	Please describe any other methods the standard uses to manage quality of service.	
Discovery and Configuration		
33.	Can the software or firmware be upgraded remotely?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Not applicable

Section II: Functional Description of the Standard

34.	Can configuration or settings be upgraded remotely?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Not applicable
35.	Can implementations announce when they have joined the system?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
36.	Can implementations electronically describe the data they provide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not applicable
System Evolution and Scalability		
37.	What factors could limit the number of places the standard could be applied?	
38.	What steps are required to increase the size of a system deploying this standard?	
39.	Is the information model separate from the transport method?	<input type="checkbox"/> Yes <input type="checkbox"/> No
40.	Does the standard support alternate choices in the layers(s) below it?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> No layers below
41.	List the most common technology choices for layers implemented below this standard	
42.	Does the standard support multiple technology choices in the layers above it?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> No layers above
43.	List the technologies or entities that would most commonly use this standard in the layer above	
44.	Please describe any mechanism or plan to ensure the standard is as backward-compatible as possible with previous versions	
45.	Please describe how the design of this standard permits it to be used together with older or legacy technologies	
46.	Please describe how the design of this standard permits it to co-exist on the same network or in the same geographic area with similar technologies, and give examples	
47.	Electromechanical	

M. Architectural Principles

Please describe how this standard may apply any of these principles:

1.	Symmetry – facilitates bi-directional flow of energy and information	
2.	Transparency – supports a transparent and auditable chain of transactions	
3.	Composition – facilitates the building of complex interfaces from simpler ones	
4.	Loose coupling – can support bilateral and multilateral transactions without elaborate pre-arrangement	
5.	Shallow integration – does not require detailed mutual information to interact with other components	

Section II: Functional Description of the Standard

6.	Please list any other architectural models, reference architectures or frameworks this standard was designed to be compliant with, e.g. W3C, IEC TC57, OSI and how it fits those models	OSI Stack Architecture and also can use TCP/IP
----	---	--