


BPA - WISP Project

NASPI Work Group Meeting
October 12-13, 2011

Scott Lissit – Project Manager, Integration
Lawrence Carter – Project Manager, PMU Installation
Nick Leitschuh – Control Center Lead
Dmitry Kosterev – Transmission Planning




Project Overview



¹ Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

² Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

BPA PMU Deployment



File Path: \\bud.bpa.gov\wg\gis_data\work\Chris\Projects\BPA Synchro Phasor Infrastructure\MXD\BPA_Synchro_Phaser_Infrastructure.mxd, User: CWL4837

Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PMUs

- **SEL 487e** chosen, with **customized features**:
 - Multicast capability
 - On-the-fly configuration for main/aux bus
 - Two fully-configurable data streams from a single PMU (PDCs and RAS)
- **Stand-alone units**, deployed in pairs or quads
- IEEE C37.118 standard, M-class
- **60 samples per second**
- Measurements:
 - Voltage and line current phasors in polar format, bus frequency, calculated line MW and MVAR, **PCB and MOD statuses**
- No PDCs in substations



PMU Installation

- **Redundant PMUs** with redundant communication paths (to two control centers)
- Current Status:
 - ✓ “Standard” designs complete
 - ✓ **6 PMUs installed at 2 initial “Beta” sites**
 - ✓ “Beta” data being analyzed
- Contractor installation (Wilson/SAIC)
- Schedule
 - Group 1 (Sites 3 – 14): February, 2012
 - Group 2 (Sites 15 – 26): June, 2012
 - Group 3 (Sites 27 – 40): October, 2012
 - Group 4 (Sites 41 – 45): March, 2013
 - Wind sites 1-10: December 2012

Communications Network


- **BPA-operated telecom network**
- SONET backbone
 - Digital microwave with legacy analog microwave
- PMU network is IP over TDM using fractional T1s. UDP protocol.
- **High-capacity routers** chosen to enable migration to future applications (Ethernet devices) and evolution of PMU requirements
- **RAS performance driving design** (latency requirements)
- **NERC CIP compliance** driving design, network monitoring
- Telecom backup battery and charger replacement required at most sites



Control Centers

- **Redundant PDCs** in each control center
 - Currently in testing, final selection not yet made
- **Control Center Architecture**
 - Evaluating feasibility of in-house design based on **OSI PI architecture** and dedicated application server
- **Data archives** in each control center (short-term), and lab (long-term)
 - Currently in testing, final selection not yet made
- Responsible for **PMU network monitoring and NERC CIP compliance**
- WISP WAN gateway
- Communications link between control centers

Network Architecture




¹¹ Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

¹² Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Applications


- **Strategy: Deploy “WASA light” and WECC shared view in Phase 1.**
- **Situational Awareness**
 - Phase angle alarm
 - Event detection
 - Oscillation Detection
 - Mode Meter (Montana Tech)
- **Engineering Applications**
 - Event analysis
 - Dynamic performance baselining
 - Model validation
- **Other applications** under development by BPA Technology Innovation:
 - Robust state estimation and contingency analysis
 - Wide area visualization



*** Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

*** Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

BPA WASA Strategy




* Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

** Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Wide Area Controls

PHASE 1


- **Developmental version of PMU-based Remedial Action Scheme (RAS)**



¹¹ Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

¹¹ Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Build on Existing Control Architecture



¹¹ Acknowledgment: This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE0000364

¹² Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Challenges

- PMU Installation
 - Short timeline
 - Scheduling equipment outages
- Telecom
 - **Equipment selection impacted by RAS latency requirements, and bandwidth for future traffic**
 - Necessity for upgrades of back-up batteries and chargers at substations
- **Cyber security**
 - PMUs will be CCAs, with associated PSP, ESP and operational requirements
- Selection/development of near-term situational awareness applications and environment (compatibility with legacy systems)
- Training for operations and maintenance of new equipment and network

Contact Information

- **Scott Lissit, PM**
360-619-6415
salissit@bpa.gov
- **Lawrence Carter, PM (PMU Installation)**
360-619-6675
ldcarter@bpa.gov
- **Nick Leitschuh, PM (Control Center, SA Apps)**
360-418-8739
nleitschuh@bpa.gov