

# Connection of embedded Generation in Ireland

EPRI Pre-conference workshop  
December 9<sup>th</sup>, Nice

Tony Hearne  
Generation Planning Manager  
ESB Networks  
ESB Ireland


# Presentation outline

- ESB's Sustainability strategy
- ESB's Strategic Framework to 2020
- Wind Penetration in Ireland
- Group Processing Approach
- Implementation to date
- Other wind specific innovations
- Conclusion

# ESB Strategic Framework to 2020 Targets

- to halve carbon emissions within 12 years
- to be carbon net-zero by 2035
- that by 2020, one third of all electricity delivered by ESB will be from renewables
- €6.5 Billion to be spent in facilitating Renewables including Smart Metering and Smart Networks
- This to include 1,400MW of wind

# Sustainability Strategy



## Internal Sustainability

A sustainable energy system connecting with energy aware interactive customers



## SmartNetwork Components

- Distributed intelligence
- Distributed energy
- Distributed communications and controls





# Smart Networks

## What do we have already ?

- SCADA /OMS
- MV Automation
- Fault indicators
- Cluster design for wind connections
- MV90
- Networks loss reductions programme (20kV, Refurb, Compact Trafo's)
- Enablers
  - Fibre Network & Radio System
  - SAP Platform

**Many of the components in place**



# Future Smart Networks

**“Build on existing components to produce an active network”**

- Intelligent automation
- Automatic device monitoring
- Self-healing network
- Cope with operation of 6000MW of wind
- Smart metering and its communications network - (The Gateway)
- Distributed generation management (micro CHP, micro wind, photovoltaics)
- Distributed storage
- Load & losses management (down to LV & individual customer)
- New network design & Control systems

**Efficient / Active Network = Smart Network**

# Background: Situation in Ireland




# Background

- Up to 2003, applications for connections for wind, were dealt with sequentially
- This was on a first come – first served basis

# Increase in Wind Applications

---

Date	Dec 3 <sup>rd</sup> , 2003
Connected	166
Contracted	534
Offered	75
In Queue	422
<b>Total MW</b>	<b>1197</b>



- At that time, the TSO [Now Eirgrid], called for a moratorium on the processing of any new wind applications until certain technical issues were resolved
- From this emerged new “wind” Grid and Distribution codes
- However this took a year to complete

# Moratorium

---


Date	Dec 3 <sup>rd</sup> , 2003	Dec 3 <sup>rd</sup> , 2004	May 3 <sup>rd</sup> , 2006
Connected	166	280	580
Contracted	534	605	641
Offered	75	98	63
In Queue	422	2295	3072
<b>Total MW</b>	<b>1197</b>	<b>3278</b>	<b>4355</b>

# GPA


- It was clear that from that point forward, the sequential processing of wind applications was no longer viable
- Ever since, applications have been dealt with under the “Group Processing Approach”

# Group Processing Approach

# Example of Sequential Approach




# Example of Sequential Approach





# Example of GPA



# Gates

- Since advent of GPA, applications have been processed in blocks called “Gates”
- Within Groups, costs for shared assets are distributed on a per/MW basis
- Periodically, following consultation with the wind industry, criterion for inclusion in a Gate are agreed
- Structure of Gates to date have been quite varied

# Gate 1 vs Gate 2


- Gate 1: 370MW: purely date order
- Gate 2:
  - Date order plus element of System optimisation
  - First 500MW in Queue “driver”
  - Applications that share a LCTA shallow connection with “driver”
  - Extensions to existing installations
  - Outliers with interactions  $<10\text{MW}$  at 110kV node
  - Resulting size circa 1385MW

# Gate 2 construction statistics

New 110kV stns	9
New 38kV stns	3
ESBN built 38kV Customer compounds	17
kms 110kV OH	48
Kms 38kV OH	80
kms 38kV UG	22
Kms MV OH	181
Kms MV UG	59
New 63MVA 110/38kV	4
New 31.5MVA 110/38kV	4
New 31.5MVA 110kV/MV	5
New 20MVA 110kV/MV	4
New 15MVA 38kV/MV	2
New 10MVA 38kV/MV	12
New 5MVA 38kV/MV	2
New 5MVA IFT	3
New 38kV booster	1
New 38kV LBFM switch	2

# Network Connections


**MW**



DSO

TSO


**Number**




DSO

TSO

# Example of Group



# Wind Capacity –v- System Demand



# Gate 3


- Gate 3 is about to start
- Currently expected to be c 4000MW
- Will be based upon Eirgrid's Grid Development Strategy out to 2025
- Transmission Firm Access dates for 110kV nodes will be published
- Distribution shallow works will be designed to fill out this capacity




## Generation Applications in 2007

	No. of Applicants			MW		
	DSO	TSO	Total	DSO	TSO	Total
<b>1st January 2007</b>	<b>83</b>	<b>21</b>	<b>104</b>	<b>1156</b>	<b>921</b>	<b>2077</b>
<b>16th November 2007</b>	<b>130</b>	<b>25</b>	<b>155</b>	<b>1901</b>	<b>1213</b>	<b>3114</b>
<b>14th December 2007</b>	<b>203</b>	<b>51</b>	<b>254</b>	<b>3259</b>	<b>3143</b>	<b>6402</b>

# Increase in Applications



# Wind Connections



2004

2007


Dec 08

# Other technical aspects

# Other innovations

- Fault Ride Through
- Frequency response
- Curtailment/Constraint
- Voltage Regulation – Power Factor Range

# Fault Ride Through



Conflict with Distribution Interface Protection  
– Under-voltage setting relaxed

# Frequency response




Figure 11 - Power-Frequency Control Curve

# Curtailment/Constraint

- Windfarms have option to connect in advance of required Transmission Deep Re-enforcements
- Where this arises, they are liable to Constraints and at some point, Curtailment
- Windfarms >5MW are required to have SCADA installed to facilitate this functionality




## Voltage Regulation – Power Factor Range

- TSO require Windfarms >5MW to be capable of providing VARs if required for Transmission System voltage support
- Therefore required to be capable of operating at a Power Factor Range of 0.95 lagging to Leading
- Conflict with Distribution shallow planning standards


## Comparison of leading vs lagging Power Factors

DG with 0.95 lagging  
PF



## Comparison of leading vs lagging Power Factors

**DG with 0.95 leading  
PF**



# 150's AAC 38kV line

- New 38k kV line design
- All wood-pole structures
- Steel masts at angles and ends eliminated
- Less visually intrusive
- Better chance of securing Planning Permission

# Conclusions

- Wind Penetration in Ireland in proportion to System load will become uniquely high
- This present many challenges
- Whilst as much as possible is connected to existing network, the sheer volume dictates the need for large new clusters
- Group Processing helps to plan these clusters efficiently
- VAr control issues to be worked out TSO-DSO

# Thank you for your attention

## Questions?